



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Clearview Regional School District

420 Cedar Road  
Mullica Hill, NJ 08062

### Results of Lead Analysis

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
Admin - Field Reagent Blank	08/25/2021 07:00	08/26/2021 20:15	<2.00	15.5	SM3113B
Admin - WF-1 Hallway 1st Floor	08/25/2021 07:01	08/26/2021 20:22	<2.00	15.5	SM3113B
Admin - S-1 Kitchen	08/25/2021 07:03	08/26/2021 20:28	<2.00	15.5	SM3113B
Admin - IM -1 Kitchen	08/25/2021 07:05	08/26/2021 20:48	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

9/13/21

Date