

**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006


**Clearview Regional School District**

420 Cedar Road  
Mullica Hill, NJ 08062

**Results of Lead Analysis**

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
Middle School - Field Reagent Blank	08/25/2021 04:40	08/26/2021 22:13	<2.00	15.5	SM3113B
Middle School - 300 Receiving - Ice Machine	08/25/2021 04:45	08/26/2021 22:20	<2.00	15.5	SM3113B
Middle School - 300 Wing By 303A - Left Machine	08/25/2021 04:48	08/26/2021 22:27	2.79	15.5	SM3113B
Middle School - 300 Wing By 300A - Right Machine	08/25/2021 04:50	08/26/2021 22:33	2.72	15.5	SM3113B
Middle School - 305 - Left Faucet	08/25/2021 04:54	08/26/2021 22:40	<2.00	15.5	SM3113B
Middle School - 305 - Right Faucet	08/25/2021 04:55	08/26/2021 22:46	<2.00	15.5	SM3113B
Middle School - 310 - Faucet	08/25/2021 05:00	08/26/2021 22:53	<2.00	15.5	SM3113B
Middle School - 310 - Fountain	08/25/2021 05:01	08/26/2021 22:59	<2.00	15.5	SM3113B
Middle School - 307 - Faucet	08/25/2021 04:58	08/26/2021 23:06	6.52	15.5	SM3113B
Middle School - Main Office Hallway - Fountain	08/25/2021 05:53	08/30/2021 14:54	<2.00	15.5	SM3113B
Middle School - Guidance - Faucet	08/25/2021 06:07	08/30/2021 15:01	<2.00	15.5	SM3113B
Middle School - Library - Faucet	08/25/2021 06:05	08/30/2021 15:07	3.58	15.5	SM3113B
Middle School - 100 Wing By 106 - Left Fountain	08/25/2021 06:10	08/30/2021 15:14	<2.00	15.5	SM3113B
Middle School - 100 Wing By 106 - Right Fountain	08/25/2021 06:11	08/30/2021 15:21	7.33	15.5	SM3113B
Middle School - 102/104 Prep - Left Faucet	08/25/2021 06:15	08/30/2021 15:41	8.35	15.5	SM3113B
Middle School - 102/104 Prep - Right Faucet	08/25/2021 06:16	08/30/2021 16:01	13.59	15.5	SM3113B
Middle School - 101/103 Prep - Left Faucet	08/25/2021 06:18	08/30/2021 16:07	11.06	15.5	SM3113B
Middle School - 101/103 Prep - Right Faucet	08/25/2021 06:19	08/30/2021 16:14	<2.00	15.5	SM3113B
Middle School - 200 Wing By 208-Cooler Fountain	08/25/2021 06:00	08/30/2021 16:20	<2.00	15.5	SM3113B
Middle School - 200 Wing By 208-Fountain	08/25/2021 06:01	08/30/2021 16:27	<2.00	15.5	SM3113B
Middle School - 414 Food Lab - Prep Faucet	08/25/2021 06:24	08/30/2021 16:33	<2.00	15.5	SM3113B
Middle School - 414 - #6 Faucet	08/25/2021 06:25	08/30/2021 16:40	<2.00	15.5	SM3113B
Middle School - 414 - #5 Faucet	08/25/2021 06:26	08/30/2021 16:59	<2.00	15.5	SM3113B
Middle School - 414 - #4 Faucet	08/25/2021 06:27	08/30/2021 17:06	<2.00	15.5	SM3113B
Middle School - 414 - #3 Faucet	08/25/2021 06:28	08/30/2021 17:12	2.57	15.5	SM3113B
Middle School - 414 - #2 Faucet	08/25/2021 06:29	08/30/2021 17:19	<2.00	15.5	SM3113B
Middle School - 414 - #1 Faucet	08/25/2021 06:30	08/30/2021 17:25	<2.00	15.5	SM3113B
Middle School - 419A - Faucet	08/25/2021 06:34	08/30/2021 17:32	<2.00	15.5	SM3113B
Middle School - 400 Wing - Left Fountain	08/25/2021 06:37	08/30/2021 17:39	<2.00	15.5	SM3113B
Middle School - 400 Wing - Right Fountain	08/25/2021 06:32	08/30/2021 17:45	<2.00	15.5	SM3113B
Middle School - 401/403 Prep - Left Faucet	08/25/2021 06:37	08/30/2021 17:52	3.59	15.5	SM3113B
Middle School - 401/403 Prep - Right Faucet	08/25/2021 06:38	08/30/2021 17:58	<2.00	15.5	SM3113B
Middle School - 402 Prep - Left Faucet	08/25/2021 06:40	08/30/2021 18:18	3.14	15.5	SM3113B
Middle School - 402 Prep - Right Faucet	08/25/2021 06:41	08/30/2021 18:38	<2.00	15.5	SM3113B
Middle School - 412 Left Faucet	08/25/2021 06:44	08/30/2021 18:45	<2.00	15.5	SM3113B
Middle School - 412 Right Faucet	08/25/2021 06:45	08/30/2021 18:51	3.28	15.5	SM3113B
Middle School - 411 Left #1 Faucet	08/25/2021 06:47	08/30/2021 18:58	3.96	15.5	SM3113B

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax


www.sjwatertest.com  
NJ DEP Certified Lab #08006

**Clearview Regional School District**

420 Cedar Road  
Mullica Hill, NJ 08062

**Results of Lead Analysis**

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
Middle School - 411 Left #2 Faucet	08/25/2021 06:48	08/30/2021 19:04	5.99	15.5	SM3113B
Middle School - 411 Right Faucet	08/25/2021 06:49	08/30/2021 19:11	6.06	15.5	SM3113B
Middle School - Teacher's Lounge (lobby) - Faucet	08/25/2021 05:26	08/30/2021 19:17	<2.00	15.5	SM3113B
Middle School - 300 Wing Teacher's Lounge Right Fountain	08/25/2021 05:28	08/30/2021 19:37	2.31	15.5	SM3113B
Middle School - 300 Wing Teacher's Lounge Left Fountain	08/25/2021 05:29	08/30/2021 19:44	<2.00	15.5	SM3113B
Middle School - 302 - Faucet	08/25/2021 05:42	08/30/2021 19:50	<2.00	15.5	SM3113B
Middle School - Nurse - Faucet	08/25/2021 05:46	08/30/2021 19:57	4.13	15.5	SM3113B
Middle School - Main Office - Faucet	08/25/2021 05:48	08/30/2021 20:04	<2.00	15.5	SM3113B
Middle School - 311 - Faucet	08/25/2021 05:05	08/30/2021 20:10	<2.00	15.5	SM3113B
Middle School - 311 - Fountain	08/25/2021 05:06	08/30/2021 20:17	<2.00	15.5	SM3113B
Middle School - Cafe By Office Double Sink - Faucet	08/25/2021 05:12	08/30/2021 20:24	41.40	15.5	SM3113B
Middle School - Cafe Chef Station - Faucet	08/25/2021 05:13	08/30/2021 20:30	<2.00	15.5	SM3113B
Middle School - Chef Prep Area - Left Faucet	08/25/2021 05:17	08/30/2021 20:37	2.31	15.5	SM3113B
Middle School - Cafe Prep Area - Right Faucet	08/25/2021 05:14	08/31/2021 11:09	<2.00	15.5	SM3113B
Middle School - 300 Wing Apr/310 - Left Fountain	08/25/2021 14:18	08/31/2021 11:28	2.52	15.5	SM3113B
Middle School - 300 Wing Apr/310 - Right Fountain	08/25/2021 14:18	08/31/2021 11:35	2.78	15.5	SM3113B

  
Mark J. Riether, Lab Director

9/13/21  
Date