

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax


www.sjwaterfest.com
NJ DEP Certified Lab #08006

Clearview Regional School District

420 Cedar Road
Mullica Hill, NJ 08062

Results of Lead Analysis

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
Field House - Field Reagent Blank	08/25/2021 07:12	08/26/2021 21:08	<2.00	15.5	SM3113B
Field House - S-1 Grounds Building	08/25/2021 07:13	08/26/2021 21:14	<2.00	15.5	SM3113B
Field House - HB-1 Grounds Building	08/25/2021 07:19	08/26/2021 21:21	<2.00	15.5	SM3113B
Field House - S-2 Kitchen 3 Bay Sink Right	08/25/2021 07:17	08/26/2021 21:27	<2.00	15.5	SM3113B
Field House - S-3 Kitchen 3 Bay Sink Left	08/25/2021 07:18	08/26/2021 21:34	<2.00	15.5	SM3113B
Field House - S-4 Kitchen Single Bay Sink	08/25/2021 07:16	08/26/2021 21:40	2.91	15.5	SM3113B
Field House - WF-1 Outside Building By Bathrooms	08/25/2021 07:25	08/26/2021 21:47	10.24	15.5	SM3113B
Field House - WF-2 Outside Building By Bathrooms	08/25/2021 07:26	08/26/2021 22:07	25.46	15.5	SM3113B



Mark J. Riether, Lab Director

9/13/21

Date